


LOUISIANA
DEPARTMENT OF HEALTH
Engineering Services

WEST WINN WATER SYSTEM INC
 Parish: WINN
 PWSID: LA1127011

2022 Water Grade

63 / 100 = 63%

D

Federal Water Quality		Points deducted for federal violations, which include Treatment Technique and Maximum Contaminant Level Violations, may pose a public health risk over an extended period of time.	Max of 30 points	-30
State Water Quality		Points deducted for state violations, which include no water operator, inadequate water disinfection, and boil notices and water outages, may lead to other issues of concern if not resolved.	Max of 10 points	-0
Financial Sustainability		Points deducted for lack of financial sustainability which can affect operations and maintenance of the water system. An effective water rate can provide for the repair, maintenance, and future replacement of infrastructure.	Max of 10 points	-0
Operations & Maintenance		Points deducted for operation and maintenance deficiencies noted during water system inspections, which may affect the water quality being distributed to consumers.	Max of 15 points	-0
Infrastructure		Points deducted for infrastructure deficiencies noted during water system inspections, which may lead to unsafe drinking water and/or water service disruption.	Max of 20 points	-0
Customer Satisfaction		Points deducted for customer complaints received by the water system and/or the Louisiana Department of Health, which are confirmed to be a water quality or quantity issue in the water system.	Max of 10 points	-7
Secondary Contaminants		Points deducted for levels of iron and/or manganese greater than the secondary maximum contaminant levels. These levels do not pose a health risk but may cause undesirable water quality issues.	Max of 5 points	-0
BONUS		Points granted for having an asset management plan; a storage assessment and maintenance program; well assessment & maintenance program; participation in management training; or participation in a capacity development program.	Max of 10 points	+0